

Report for In Service Inspection and Testing of Electrical Equipment

APPLIANCE DETAILS													FORMAL VISUAL INSPECTION DATE & INITIAL JAN 2012	INSPECTION & TEST DETAILS															
40 LINE	LOG No.	DATE TESTED	APPLIANCE	DETAILS	DEPARTMENT	LOCATION	SERIAL NUMBER	ASSET NUMBER	CLASS	VOLTAGE	TYPE	CONNECTION TO MAINS		FUSE	VISUAL	REPAIRS / OBSERVATIONS	CONTINUITY Ω			INSULATION $M\Omega$			TOUCH CURRENT		SAFE TO USE?	NOTES	1 MW RF TEST	0 RCD TEST	PAT SERIAL NUMBER
																TEST	RESULT	PREVIOUS	TEST	RESULT	PREVIOUS	RESULT	PREVIOUS						
1	911	14/06/2011	AC Adaptor	Potrans	Garden	Office			2	240v	IT	Plug	N/A	3	PASS		N/A		:	:	N/A		:	:	PASS			31B-0970	
2	1101184	14/06/2011	IEC Lead		Garden	Office			1	240v	IT	Plug	N/A	3	PASS		200mA	0.08	0.08 : 0.09	500V DC	>99	>99 : >99		:	:	PASS		31B-0970	
3	909	14/06/2011	Engraving Machine	Gravograph	Garden	Office	50901		1	240v	IT	Plug	N/A	3	PASS		200mA	0.08	0.07 : 0.08	Sub		:	:	<1mA	<1mA :	PASS		31B-0970	
4	23776	14/06/2011	AC Adaptor	Motorola	Garden	Office			2	240v	IT	Plug	N/A	N/A	PASS		N/A		:	:	N/A		:	:	PASS		31B-0970		
5	1101181	14/06/2011	IEC Lead		Garden	Office			1	240v	IT	Plug		5	PASS		200mA	0.06	0.06 : 0.07	500V DC	>99	>99 :		<1mA :	:	PASS		31B-0970	
6	913	14/06/2011	AC Adaptor	Motorola	Garden	Office			1	240v	IT	Plug	N/A	5	PASS		200mA	0.05	0.06 : 0.06	Sub		:	:	<1mA	<1mA :	PASS		31B-0970	
7	916	14/06/2011	Battery Charger	Energiser	Garden	Office			2	240v	Portable	Plug	N/A	N/A	PASS		N/A		:	:	N/A		:	:	PASS		31B-0970		
8	1101178	14/06/2011	IEC Lead		Garden	Office			1	240v	IT	Plug	N/A	5	PASS		200mA	0.06	0.09 :	500V DC	>99	>99 :		:	:	PASS		31B-0970	
9	16674	14/06/2011	PC	HJP	Garden	Office	CZC1028JGF	IS00277	1	240v	IT	Plug	N/A	5	PASS		200mA	0.06		Sub				<1mA		PASS		31B-0970	
10	1101177	14/06/2011	IEC Lead		Garden	Office			1	240v	IT	Plug	N/A	5	PASS		200mA	0.07		500V DC	>99					PASS		31B-0970	
11	1036	14/06/2011	Monitor	HP	Garden	Office	CND6382K4G	IT89380	1	240v	IT	Plug	N/A	5	PASS	F	200mA	0.09	0.09 : 0.1 :	Sub		:	:	<1mA	<1mA :	PASS		31B-0970	
12	23766	14/06/2011	Microwave	Samsung	Garden	Kitchen	20407DCS700039XW		1	240v	Stationary	Plug	N/A	13	PASS		200mA	0.02	0.04 :	500V DC	>99	>99 :		:	:	PASS	0.69	31B-0970	
13	23767	14/06/2011	Fridge	Bosch	Garden	Kitchen	387647		1	240v	Stationary	Plug	N/A	13	PASS	O	200mA	0.06	0.06 :	500V DC	>99	>99 :		:	:	PASS		31B-0970	
14	902	14/06/2011	Toaster	Hinari	Garden	Kitchen			1	240v	Portable	Plug		13	PASS		200mA	0.03	0.03 : 0.03	500V DC	>99	>99 : >99		:	:	PASS		31B-0970	
15	16673	14/06/2011	Kettle	Breville	Garden	Kitchen			1	240v	Portable	Plug		13	PASS		200mA	0.06		500V DC	>99					PASS		31B-0970	
16	23768	14/06/2011	Kettle	Tefal	Garden	Kitchen			1	240v	Portable	Plug		13	PASS		200mA	0.06	0.06 : 0.04	500V DC	>99	>99 : >99		:	:	PASS		31B-0970	
17	16671	14/06/2011	Hedge Trimmer	Little Wonder	Garden	Workshop			2	110v	Industrial	Plug		N/A	PASS		N/A			500V DC	>99					PASS		31B-0970	
18	890	14/06/2011	Hedge Trimmer	Little Wonder	Garden	Workshop	371912		2	110v	Industrial	Plug		N/A	PASS		N/A		:	:	500V DC	>99	>99 : >99		:	:	PASS		31B-0970
19	880	14/06/2011	Hedge Trimmer	Little Wonder	Garden	Workshop	367664		2	110v	Industrial	Plug		N/A	PASS		N/A		:	:	500V DC	>99	>99 :		:	:	PASS		31B-0970
20	16670	14/06/2011	Multiway Adaptor	Gewiss	Garden	Workshop			1	110v	Industrial	Plug		N/A	PASS		200mA	0.01		500V DC	>99					PASS		31B-0970	
21	23762	14/06/2011	Extension Lead	GET	Garden	Workshop			1	240v	Industrial	Plug		13	PASS		200mA	0.29	0.29 : 0.27	500V DC	>99	>99 :		:	:	PASS		31B-0970	
22	16669	14/06/2011	Extension Lead	Permaplug	Garden	Workshop			1	240v	Industrial	Plug		13	PASS		200mA	0.1		500V DC	>99					PASS		31B-0970	
23	16668	14/06/2011	Extension Lead	Permaplug	Garden	Workshop			1	240v	Industrial	Plug		13	PASS		200mA	0.08	0.08 : 0.08	500V DC	>99	>99 : >99		:	:	PASS		31B-0970	
24	887	14/06/2011	Extension Lead	Britticut	Garden	Workshop			1	240v	Industrial	Plug		13	PASS		200mA	0.05	0.06 : 0.06	500V DC	>99	>99 : >99		:	:	PASS		31B-0970	
25	23758	14/06/2011	Extension Lead 16A Plug > 13A Socket	Permaplug	Garden	Workshop			1	240v	Industrial	Plug		N/A	PASS		200mA	0.02	<0.04 : <0.04 :	500V DC	>99	>99 :		:	:	PASS		31B-0970	