



In Service Inspection Testing of Electrical Equipment Report

APPLIANCE DETAILS						INSPECTION DETAILS															RECORDED INSPECTION					
LOG No.	DATE	APPLIANCE	DETAILS	LOCATION	SERIAL NUMBER	CORD	FUSE	VISUAL	CONTINUITY Ω					INSULATION $M\Omega$					SAFE TO USE?	NOTES	Jul-07	Oct-07	Jan-08			
									Test	2003	2004	2005	2006	2007	Test	2003	2004	2005						2006	2007	
70039	12/04/2007	Insectecutor	Insectaflash	Restaurant Servery	0048M	OK	5	OK	10 Amp	0.11	0.11	0.12	0.13	0.12	500V DC	>99	>99	>99	>99	>99	Yes					
70040	12/04/2007	IEC Lead	<p>The purpose of appliance testing is to provide a year on year analysis of the condition of the appliance so as to monitor any deterioration. To just say "PASS" is not enough, GTI supply test data for a comparison between results.</p> 									-	-	0.15	0.15	500V DC	-	-	-	>99	>99	Yes				
70041	12/04/2007	Soup Pot										-	-	0.11	0.11	0.1	500V DC	>99	>99	>99	>99	86.65	Yes			
70042	12/04/2007	Water Urn										-	-	-	-	0.05	500V DC	-	-	-	-	>99	Yes			
70043	12/04/2007	Refrigerator										-	-	0.06	0.08	0.07	500V DC	>99	>99	>99	21.82	31.81	Yes			
70044	12/04/2007	Milk Chiller	Cornelius	Restaurant Servery	42499803	OK	10	OK	10 Amp	0.04	0.04	0.04	0.06	0.06	500V DC	>99	>99	>99	>99	>99	Yes					
70045	12/04/2007	Ice Maker	Hoshizaki	Restaurant Servery	5707	OK	5	OK	10 Amp	0.06	0.06	0.07	0.08	0.08	500V DC	>99	>99	>99	>99	>99	Yes					
70046	12/04/2007	Wine chiller	Samsung	Restaurant Servery	800176P	OK	13	OK	10 Amp	-	-	0.06	0.08	0.07	500V DC	-	-	>99	>99	>99	Yes					
70047	12/04/2007	Ice Cream Cabinet	Norfrost	Restaurant Servery	87139	OK	13	OK	10 Amp	-	0.06	0.06	0.07	0.08	500V DC	-	>99	>99	>99	>99	Yes					
70048	12/04/2007	Fan	Homebase	Restaurant Servery	2200309	OK	3	OK	Class II	-	-	-	-	-	-	-	-	-	-	-	Yes					
70051	12/04/2007	PDQ AC Adap	Ingenico	Restaurant Servery	-	OK	3	OK	Class II	-	-	-	-	-	<p>In line with the Code of Practice, GTI also provide guidance as to when the intermediate recorded visual inspections are due.</p> 											
70052	12/04/2007	Modem AC Adap	US Robotics	Restaurant Servery	-	OK	-	OK	Class II	-	-	-	-	-												
70053	12/04/2007	IEC Lead	-	Restaurant Servery	-	OK	5	OK	10 Amp	-	-	-	0.05	0.04												
70054	12/04/2007	Air Freshener	Prozone	Restaurant Toilets	-	OK	3	OK	-	-	-	-	-													
70055	12/04/2007	Slicer	Comercia	Restaurant 1st FI Kitchen	A04264	OK	10	OK	25 Amp	0.08	0.08	0.08	0.08	0.08	500V DC	>99	>99	>99	>99	>99	Yes					
70056	12/04/2007	Milk Cooler	Cornelius	Restaurant 1st FI Kitchen	74989605	OK	10	OK	25 Amp	0.05	0.06	0.05	0.05	0.05	500V DC	>99	>99	>99	>99	>99	Yes					
70057	12/04/2007	Refrigerator	Foster	Restaurant 1st FI Kitchen	E208171	OK	13	OK	25 Amp	0.06	0.06	0.05	0.05	0.05	500V DC	>99	>99	>99	>99	>99	Yes	Power off				
70058	12/04/2007	Hot Pots	Lincat	Restaurant 1st FI Kitchen	21016610	OK	10	OK	25 Amp	0.04	0.05	0.05	0.04	0.04	500V DC	>99	>99	51.46	>99	>99	Yes					
70059	12/04/2007	Hot Plate	Victor	Restaurant 1st FI Kitchen	49707971	OK	13	OK	25 Amp	-	0.05	0.05	0.07	0.05	500V DC	-	13.34	9.26	9.43	9.28	Yes					
70060	12/04/2007	Coffee Pot Warmer	Bravilor	Restaurant 1st FI Kitchen	287844	OK	13	OK	25 Amp	0.08	0.07	0.08	0.08	0.06	500V DC	>99	>99	>99	>99	>99	Yes					
70061	12/04/2007	Coffee Maker	Bravilor	Restaurant Servery	20060036648	OK	13	OK	10 Amp	-	-	0.08	0.08	0.04	500V DC	-	-	-	-	>99	Yes					
70062	12/04/2007	Coffee Maker	Bravilor	Restaurant Servery	20067074557	OK	13	OK	10 Amp	-	-	-	-	-	>99	Yes										
70063	12/04/2007	Cash Register	Sharp	Restaurant Servery	68001635	OK	3	OK	100mA	0.0	0.0	0.0	0.0	0.0	<1.00mA	Yes										
70064	12/04/2007	Cash Register	Sharp	Restaurant Servery	68002335	OK	3	OK	100mA	0.0	0.0	0.0	0.0	0.0	<1.00mA	Yes										
70065	12/04/2007	Water Vending Machine	Pacifik	Restaurant Servery	P070005302	OK	5	OK	25 Amp	-	-	-	-	-	>99	Yes										
70066	12/04/2007	Extn Lead 20m	Faithful	Library	SCEX001	OK	13	OK	25 Amp	0.29	0.3	0.3	0.31	500V DC	>99	>99	>99	>99	>99	Yes	20m.					
70067	12/04/2007	IEC Lead	-	Restaurant 1st FI Kitchen	-	OK	13	OK	25 Amp	-	-	-	0.09	0.09	500V DC	-	-	-	>99	>99	Yes					
70068	12/04/2007	Amp	RCF	Restaurant 1st FI Kitchen	170221770	OK	13	OK	10 Amp	-	-	-	0.1	0.1	500V DC	-	-	-	>99	>99	Yes					
70069	12/04/2007	Humidistat	Hanwell	Library	14184	OK	13	OK	100mA	0.04	0.05	0.05	0.06	0.06	Sub	-	<0.2mA	<0.2mA	<0.2mA	<1.00mA	Yes					
70070	12/04/2007	Radiator	DeLonghi	Library	64704	OK	13	OK	25 Amp	0.06	0.06	0.04	0.04	0.04	500V DC	>99	>99	>99	>99	>99	Yes					